



# CITY OF ESCALON

---

## Notice of Change to Cross Connection Control Program

As of March 1, 2014, the City of Escalon is making changes and additions to the Cross Connection Control Program. The City now requires that test results be submitted on the City of Escalon Backflow Prevention Assembly Test Report Form. A copy of the required form is enclosed with this letter and is also available for download off our website:

<http://cityofescalon.org/departments/public-works/water-department/>

We are also requiring that backflow device certifications submitted to the City have the 3 PSID Buffer (difference between the readings for check valve #1 and relief valve opening point) as required in the Ninth Edition, Manual of Cross Connection Control. This amendment by the City will be in effect until further notice.

Device certifications submitted without the required buffer will be considered a device failure and will be rejected. Questions regarding these changes can be directed to the Public Works Department 209-691-7470.

Regards,

Matthew Morgan  
Chief Water System Operator  
Public Works Department | City of Escalon