


NOTES:

1. REFER TO CITY HANDOUT E61 FOR ADDITIONAL DESIGN AND PERMIT REQUIREMENTS.
2. ASSEMBLIES SHOULD NOT BE PLACED IN AREAS SUBJECT TO VEHICULAR TRAFFIC. IF LOCATED IN TRAFFIC AREAS, THE LID SHALL BE TRAFFIC RATED AND SHALL BE INSTALLED FLUSH IN ASPHALT OR CONCRETE.

**CITY INSPECTION REQUIRED
PRIOR TO BACKFILL**



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**36" DUPLEX GRINDER
PUMP WITH REMOTE
MOUNTED CONTROL PANEL**

APPROVED BY: R. ENGLISH

REVISION DATE
OCTOBER 2021

STANDARD
DETAIL
SS-242