



SERVICE PEDESTAL DETAIL

PULL BOX DETAIL
N.T.S

NOTES:

1. SERVICE PEDESTAL SHALL BE MYERS ELECTRIC PRODUCTS MEUGO16-M100 OR EQUAL.
2. CIRCUIT BREAKERS SHALL BE SUITABLE FOR USE ON 120/240 VOLT SERVICE AND SHALL BE APPROVED BY UNDERWRITERS LABORATORY.
3. CABINET SHALL BE BONDED TO CONDUIT WITH COPPER GROUND WIRE EQUIVALENT TO NO. 6 A.W.G.
4. PULL BOX SHALL BE INSTALLED NEXT TO BASE WITH 2" SCH. 80 CONDUIT, MINIMUM.
5. SCH 80 CONDUITS SHALL EXTEND INTO CABINET 1' ABOVE FLOOR AND HAVE APPROVED CONDUIT BUSHING.
6. CONTRACTOR SHALL MAKE ARRANGEMENTS WITH UTILITY FOR 120/240 VOLT SERVICE AND SHALL BE RESPONSIBLE FOR ANY CHARGES BY THE UTILITY FOR ANY WORK.
7. PULL BOXES SHALL BE PLACED ON ONCOMING TRAFFIC SIDE OF POLES. TOP TO BE FLUSH WITH ADJACENT GRADE. KNOCK OUT TO BE SEALED WITH GROUT AFTER CONDUIT INSTALLATION. ALL PULL BOXES SHALL HAVE PENTA-HEAD LOCKING LIDS (PER CAL TRANS SPEC ES-8A) CONTRACTOR SHALL PROVIDE ALL LOCKS (PENTA-HEAD SOCKETS) FOR LIDS TO PW TRAFFIC DIVISION.

CITY OF SAN BERNARDINO PUBLIC WORKS DEPARTMENT

APPROVED Coll/22

STANDARD NO.

STREET LIGHT SERVICE PEDESTAL
AND PULL BOX DETAILS

Alex Quinlan
CITY ENGINEER

SL-2