



NOTE:
REFER TO VILLAGE STANDARD SPECIFICATIONS FOR STORM SEWER.

STRUCTURE DIAMETER	MIN WALL THICKNESS*	MIN BASE AND TOP THICKNESS*
4'	5"	6"
5'	6"	8"
6'	7"	8"
7'	8"	8"
8' AND GREATER	9"	8"

* MINIMUM THICKNESS SHALL NOT BE LESS THAN THAT REQUIRED TO MEET AASHTO H-20 LOADINGS

SCALE: NTS

STANDARD STORM MANHOLE

DETAIL: STM - 1

DATE: 1-23-20

APPROVED BY: MATT FINEOUR

VILLAGE OF PLEASANT PRAIRIE
KENOSHA COUNTY, WISCONSIN