



# LOS ALAMOS

## Fire Marshal's Office

999 Central Ave., Suite 200, Los Alamos, NM 87544  
Phone (505) 662-8301 • Fax (505) 662-8302



### AUTOMATIC FIRE SPRINKLER SYSTEM PLANS SUBMITTAL CHECKLIST NFPA 13 (2019 EDITION)

---

Occupancy Name

---

Occupancy Address

---

Company Name and Address of Design Professional, Contractor or Contractor's Representative

---

Email and Phone Number of Design Professional, Contractor or Contractor's Representative

The following Fire Sprinkler Plans Submittal Checklist is required information for fire sprinkler permit review. Use of the form does not guarantee that plans will be accepted on the first submittal, but will aid in reducing the number of re-submittals required due to the lack of information or conflicting information being provided. **This checklist should not be considered to be all inclusive. Additional information may be required. Use of this checklist will not eliminate the requirement for a good knowledge and understanding of NFPA 13.**

For issuance of the fire sprinkler permit and prior to any installation and request for fire sprinkler concealment inspections, the following information and/or forms shall be completed, submitted and approved.

- Fire System permit application.
- An electronic set of plans in PDF or TIF format, or provide three (3) printed sets of shop drawings/plans. (1 each for the Fire Marshal, Contractor, and Owner, if As-Built drawings are required at project completion provide 3 corrected sets for approval)
- Payment for permit fees if applicable.

***Any material installed or work performed prior to the issuance of a permit will be subject to two times the permit fee and/or required to be removed. A hard copy of the permit and an approved set of plans are required to be maintained on the job site at all times and must be on site prior to any worked being performed unless a limited early start request has been granted. Limited early start requests are considered on a case by case basis, are required to be submitted in writing on letter head and are not automatically granted.***

**23.1.1 Working plans shall be submitted for approval to the authority having jurisdiction before any equipment is installed or remodeled.**

**23.1.2 Deviation from approved plans shall require permission of the authority having jurisdiction.**

**23.1.3 Working plans shall be drawn to an indicated scale, on sheets of uniform size, with a plan of each floor, and shall show those items from the following list that pertain to the design of the system:**

- (1) Name of owner and occupant
- (2) Location, including street address
- (3) Point of compass
- (4) Full height cross section, or schematic diagram, including structural member information if required for clarity and including ceiling construction and method of protection for nonmetallic piping
- (5) Location of partitions
- (6) Location of fire walls
- (7) Occupancy class of each area or room
- (8) Location and size of concealed spaces, closets, attics, and bathrooms
- (9) Any small enclosures in which no sprinklers are to be installed
- (10) Size of city main in street and whether dead end or circulating; if dead end, direction and distance to nearest circulating main; and city main test results and system elevation relative to test hydrant (see A.15.1.8).



## AUTOMATIC FIRE SPRINKLER SYSTEM PLANS SUBMITTAL CHECKLIST NFPA 13 (2013 EDITION)



- (11) Other sources of water supply, with pressure or elevation
- (12) Make, type, model, and nominal K-factor of sprinklers including sprinkler identification number
- (13) Temperature rating and location of high-temperature sprinklers
- (14) Total area protected by each system on each floor
- (15) Number of sprinklers on each riser per floor
- (16) Total number of sprinklers on each dry pipe system, preaction system, combined dry pipe- preaction system, or deluge system
- (17) Approximate capacity in gallons of each dry pipe system
- (18) Pipe type and schedule of wall thickness
- (19) Nominal pipe size and cutting lengths of pipe (or center to center dimensions). Where typical branch lines prevail, it shall be necessary to size only one typical line
- (20) Location and size of riser nipples
- (21) Type of fittings and joints and location of all welds and bends. The contractor shall specify on drawing any sections to be shop welded and the type of fittings or formations to be used
- (22) Type and locations of hangers, sleeves, braces, and methods of securing sprinklers when applicable
- (23) All control valves, check valves, drain pipes, and test connections
- (24) Make, type, model, and size of alarm or dry pipe valve
- (25) Make, type, model, and size of preaction or deluge valve
- (26) Kind and location of alarm bells
- (27) Size and location of standpipe risers, hose outlets, hand hose, monitor nozzles, and related equipment
- (28) Private fire service main sizes, lengths, locations, weights, materials, point of connection to city main; the sizes, types and locations of valves, valve indicators, regulators, meters, and valve pits; and the depth that the top of the pipe is laid below grade
- (29) Piping provisions for flushing
- (30) Where the equipment is to be installed as an addition to an existing system, enough of the existing system indicated on the plans to make all conditions clear
- (31) For hydraulically designed systems, the information on the hydraulic data nameplate
- (32) A graphic representation of the scale used on all plans
- (33) Name and address of contractor
- (34) Hydraulic reference points shown on the plan that correspond with comparable reference points on the hydraulic calculation sheets
- (35) The minimum rate of water application (density), the design area of water application, in-rack sprinkler demand, and the water required for hose streams both inside and outside
- (36) The total quantity of water and the pressure required noted at a common reference point for each system
- (37) Relative elevations of sprinklers, junction points, and supply or reference points
- (38) If room design method is used, all unprotected wall openings throughout the floor protected
- (39) Calculation of loads for sizing and details of sway bracing
- (40) The setting for pressure-reducing valves
- (41) Information about backflow preventers (manufacturer, size, type)
- (42) Information about antifreeze solution used (type and amount)  
*Item 42 of 23.1.3 was revised by a tentative interim amendment (TIA). See page 1.*
- (43) Size and location of hydrants, showing size and number of outlets and if outlets are to be equipped with independent gate valves. Whether hose houses and equipment are to be provided, and by whom, shall be indicated. Static and residual hydrants that were used in flow tests shall be shown
- (44) Size, location, and piping arrangement of fire department connections
- (45) Ceiling/roof heights and slopes not shown in the full height cross section.
- (46) Edition year of NFPA 13 to which the sprinkler system is designed.

### 23.2.1 Water Supply Information.

#### The following information shall be included:

- (1) Location and elevation of static and residual test gauge with relation to the riser reference point
- (2) Flow location
- (3) Static pressure, psi (bar)
- (4) Residual pressure, psi (bar)
- (5) Flow, gpm (L/min)



**AUTOMATIC FIRE SPRINKLER SYSTEM  
PLANS SUBMITTAL CHECKLIST NFPA 13 (2013 EDITION)**



- (6) Date
- (7) Time
- (8) Test conducted by or information supplied by
- (9) Other sources of water supply, with pressure or elevation

**23.3.2 The summary sheet shall contain the following information, where applicable:**

- (1) Date
- (2) Location
- (3) Name of owner and occupant
- (4) Building number or other identification
- (5) Description of hazard
- (6) Name and address of contractor or designer
- (7) Name of approving agency
- (8) System design requirements, as follows:
  - (a) Design area of water application, ft<sup>2</sup> (m<sup>2</sup>)
  - (b) Minimum rate of water application (density), gpm/ft<sup>2</sup> (mm/min)
  - (c) Area per sprinkler, ft<sup>2</sup> (m<sup>2</sup>)
- (9) Total water requirements as calculated, including allowance for inside hose, outside hydrants, and water curtain and exposure sprinklers
- (10) Allowance for in-rack sprinklers, gpm (L/min)
- (11) Limitations (dimension, flow, and pressure) on extended coverage or other listed special sprinklers

**23.3.3 Detailed Worksheets.** Detailed worksheets or computer printout sheets shall contain the following information:

- (1) Sheet number
- (2) Sprinkler description and discharge constant (K)
- (3) Hydraulic reference points
- (4) Flow in gpm (L/min)
- (5) Pipe size
- (6) Pipe lengths, center-to-center of fittings
- (7) Equivalent pipe lengths for fittings and devices
- (8) Friction loss in psi/ft (bar/m) of pipe
- (9) Total friction loss between reference points
- (10) In-rack sprinkler demand balanced to ceiling demand
- (11) Elevation head in psi (bar) between reference points
- (12) Required pressure in psi (bar) at each reference point
- (13) Velocity pressure and normal pressure if included in calculations
- (14) Notes to indicate starting points or reference to other sheets or to clarify data shown
- (15)\*Diagram to accompany gridded system calculations to indicate flow quantities and directions for lines with sprinklers operating in the remote area
- (16) Combined K-factor calculations for sprinklers on drops, armovers, or sprigs where calculations do not begin at the sprinkler

---

**Occupancy Name**

---

**Occupancy Address**

**I attest that all applicable information noted above has been provided for review and approval and accept responsibility for its content, errors or omissions.**

---

**Name of Design Professional, Contractor or Contractor's Representative**

**Date**