



PROPANE TANKS PLANS REVIEW

Mechanical or Plumbing:

- Gas type.
- Isometric of piping layout (including location of regulators).
- Longest run of gas pipe (from source to farthest outlet).
- Pipe type, size(s) and gas pressures.
- Appliance(s) BTUH rating.
- Gas table used for sizing.

Building:

- Propane tanks require anchoring details.

Site plan required.

NOTE: A reference note indicating the specific sizing chart from FBC Fuel Gas 7th Edition (2020) or NFPA58 2017 Edition can be added to the piping isometric to save uploading the sizing chart.

Code Reference:

FBC Building 7th Edition (2020) Section 107.3.5

FBC Plumbing 7th Edition (2020)

FBC Fuel Gas 7th Edition (2020) Fuel Gas.

This document is intended to be a guide and may not contain all requirements needed to obtain permits and approval from Manatee County.

**Building and Development Services
1112 Manatee Ave W 4th Floor Bradenton, FL 34205
www.mymanatee.org**

JAMES
SATCER
District 1

REGGIE
BELLAMY
District 2

KEVIN
VAN OSTENBRIDGE
District 3

MISTY
SERVIA
District 4

VANESSA
BAUGH
District 5

CAROL
WHITMORE
At Large

GEORGE W.
KRUSE
At Large